

## How to apply the patch 2.5 in the SC-DAD

### Topics in this document

Patch 2.5 features.....	1
How to apply the patch 2.5.....	1

### Patch 2.5 features

- Added the get network settings function (for more details please read the SC-DAD manual)
- Added the Gateway option in the USB ip recovery procedure (for more details please read the manual)
- Manual Upgrade (new functions reference)

### How to apply the patch 2.5

**Note: this patch will reboot the device: the data acquisition will be stopped for 20 seconds.**

**The Patch is applicable only for firmware versions 2.x and it include all previous patches.**

- 1) Click on the Tools menu button from the web configuration software



- 2) Insert the system password if asked (default password: root) and then click to the login button



3) Click on the Software Upgrade/Backup Restore button

Change admin password:	<input type="button" value="Change"/>
Software Upgrade/Backup Restore:	<input type="button" value="Proceed"/>
Full system backup:	<input type="button" value="Backup Now"/>

4) Select the patch 2.5 file and use “send” button to start the upgrade

Device Tools

Choose a SC-DAD bin file:

5) A white page will appear, then wait for the device automatic reboot (10 seconds).